



December 26, 2023

Chris Merritt
209 Crescent Beach Dr.
Packwood, WA 98361

RE: WS23-00049
Expiration: 12/15/2025

Dear Mr. Merritt.

Enclosed is a copy of the completed well site inspection for a proposed well to be drilled on TP#035067002003. The well is intended to serve as a water supply source for a Group B water system serving residential connections. The proposed well location, 121°39'32.996"W 46°38'6.621"N, is satisfactory with establishment of a protective Declaration of Covenant on the 100' radius Sanitary Control Area. The well must be drilled consistent with construction standards as required in WAC173-160. The well development must include seating and sealing the well cap and installing impervious electrical conduit. If completed in the 100-yr flood zone, the well casing top must be at least 2-ft above the flood plain elevation. The pumphouse must be built such that it is rodent proof, insulated, and weather tight, and at least 2-ft above the flood plain elevation.

Approval of a well site or preliminary plat does not constitute or imply approval of the proposed water system or subsequent permitting. Approval of the water system is contingent upon the water system construction and management plan meeting Lewis County Code 8.55 and the rules and regulations of the State of Washington.

If you have any questions, please call me at (360)740-1249.

Sincerely,

Jeff Landrum RS LG
Environmental Health Specialist, Water Program
2025 NE Kresky Ave. Chehalis, WA 98532

Attachments: Proposed Well Site Aerial Map
Well Site Inspection Form

Cc: Robert Balmelli PO Box 923 Chehalis, WA 98532